

HB 1067

SUBCOMMITTEE

1. Line 297, introduced, after of

strike

4.0

insert

3.0

SUBCOMMITTEE

2. At the beginning of line 298, introduced

strike

0.30

insert

0.22

SUBCOMMITTEE

3. After line 376, introduced

insert

2. That the nutrient technology requirements of 3.0 mg/L total nitrogen and 0.22 mg/L total phosphorus for the Fredericksburg Waste Water Treatment Facility established in the first enactment clause of this act shall take effect and apply on an annual basis when the expanded Fredericksburg Waste Water Treatment Facility receives its certificate to operate.